

**Detail \* E/A**


**ACHTUNG!**  
Zu-/Ablaufrohr Behälter  
nicht bündig abschneiden  
10cm Überstand erforderlich

**Wichtig für die Montage:**  
Die Schachtabdeckung mit  
Lüftungsöffnung gehört über  
den 3. Behälter (Biologie)  
Die Überdeckung auf  
dem Behälter darf max.  
50cm betragen  
(Domverlängerung verfügbar)

**Legende:**  
E... Einlauf: Muffe KG 160  
A... Ablauf: Muffe KG 160  
B... Schutzrohr: Schlamm KG 110  
C... Schutzrohr: Belüftung/ELT KG 110  
Z1: Muffe KG 160  
Z2: Muffe KG 160  
Z3: Rohr Ø40

**EMANO 3 Behälter 30 - 35 EW**

EW	Typ	Breite									Gesamt Gewicht (kg)
			X1	X2	X3	X4	X5	X6	X7	X8	
30	2-2-3	2200	1900	1450	1350	1300	1550	1500	1450	2150	1300
35	2-2-4	2200	1900	1450	1350	1300	1650	1600	1550	2250	1400



Datum	Name	Bergmann Beton + Abwassertechnik GmbH Am Zeisig 8 09322 Penig OT Wernsdorf Tel.: 03 73 81 / 861 - 0 Fax: 03 73 81 / 861 - 50 Tel.: 03 73 81 / 861 - 37 Fax: 03 73 81 / 861 - 36	Blatt 1/1	
Bearbeiter:	21.05.2023			K. Wagner
Geprüft:	21.05.2023			J. Ilian
Norm: EN 12566-3		Benennung: <b>wsb® Typ3 - 30-35, Klasse C und N</b> <b>Kunststoffanlage PE DN 2200</b>	Werkstoff: 9002-88-4	
Projekt / Bezeichnung: EMANO Kammertank 30/35 EW				Zeichnungsnr.: EMANO_3 Kammertank_30_35_DN2200_20230521.dwg
Allgemeintoleranz:		Projektnr.:	Format: DIN A4	

The reproduction, distribution and utilization of this document as well as the communication of its contents to others without express authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of a patent, utility model or design.